



DATE: April 13, 2004  
TO: **Ex. 6 - Personal Privacy**  
FROM: Jeff Smith  
SUBJECT: Water Testing Results

---

Attached are the results of the water samples taken from your bathroom sink on April 2, 2004. The results indicate the level of nitrate (2.53 milligrams per liter) is below the drinking water standard of 10 milligrams per liter.

Paragraph 34 of the "Order on Consent" required Mountaire Farms to provide an emergency supply of drinking water until a permanent alternate water supply is installed. With the installation of the ion exchange unit and the results of this sampling showing the water to be compliant with drinking water standards, please be advised that Mountaire Farms will be discontinuing the supply of bottled water.

Please contact me at (302) 934-3094 so that the dispenser and remaining containers of water can be removed from your residence.

We appreciate your cooperation in this matter and as always, if you have any questions, please do not hesitate to contact me at the number above.

A handwritten signature in black ink, appearing to read "Jeff Smith", written over a horizontal line.

Jeffrey Smith, REM  
Environmental Manager



**Mountaire Farms of Delaware, Inc.**  
P.O. Box 1320, Millsboro, Delaware 19966  
(302) 934-1100 Toll Free (877) 887-1490

*"We measure quality by how well we service our internal and external customers"*

**ENVIROCORP****Labs**

14 Commerce Street • Harrington, DE 19952 • (302) 398-4313 • FAX: (302) 398-4312  
info@envirocorplabs.com

04/12/04

Mountaire Poultry  
P.O. Box 1320  
Millsboro, DE 19966

Attention: Mr. Jeff Smith

Lab I.D.Description

13196D

**Ex. 6 - Personal Privacy** 1020-hrs on 4/2/04 by client:  
received 4/2/04 by CMG of EI

ParameterUnitsResultsTest DateTime InitMethod

Nitrate as N

mg/L

2.53

04/09/04

1420

EHK

4500

**Ex. 6 - Personal Privacy**

Supervising Analyst





DATE: March 29, 2004  
TO: Ex. 6 - Personal Privacy  
FROM: Jeff Smith  
SUBJECT: Water Testing Results

---

Attached are the results of the water samples taken from your kitchen sink on March 23, 2004. The results indicate the level of nitrate (<1.0 milligram per liter) is below the drinking water standard of 10 milligrams per liter.

Paragraph 34 of the "Order on Consent" required Mountaire Farms to provide an emergency supply of drinking water until a permanent alternate water supply is installed. With the installation of the ion exchange unit and the results of this sampling showing the water to be compliant with drinking water standards, please be advised that Mountaire Farms will be discontinuing the supply of bottled water.

Please contact me at (302) 934-3094 so that the dispenser and remaining containers of water can be removed from your residence.

We appreciate your cooperation in this matter and as always, if you have any questions please do not hesitate to contact me at the number above.

---

Jeffrey Smith, REM  
Environmental Manager



**Mountaire Farms of Delaware, Inc.**  
P.O. Box 1320, Millsboro, Delaware 19966  
(302) 934-1100 Toll Free (877) 887-1490

*"We measure quality by how well we service our internal and external customers"*

ED\_001654\_00000762-00004



DATE: March 29, 2004  
TO: **Ex. 6 - Personal Privacy**  
FROM: Jeff Smith  
SUBJECT: Water Testing Results

---

Attached are the results of the water samples taken from your kitchen sink on March 23, 2004. The results indicate the level of nitrate (1.48 milligram per liter) is below the drinking water standard of 10 milligrams per liter.

Paragraph 34 of the "Order on Consent" required Mountaire Farms to provide an emergency supply of drinking water until a permanent alternate water supply is installed. With the installation of the ion exchange unit and the results of this sampling showing the water to be compliant with drinking water standards, please be advised that Mountaire Farms will be discontinuing the supply of bottled water.

Please contact me at (302) 934-3094 so that the dispenser and remaining containers of water can be removed from your residence.

We appreciate your cooperation in this matter and as always, if you have any questions please do not hesitate to contact me at the number above.

---

Jeffrey Smith, REM  
Environmental Manager



**Mountaire Farms of Delaware, Inc.**  
P.O. Box 1320, Millsboro, Delaware 19966  
(302) 934-1100 Toll Free (877) 887-1490

*"We measure quality by how well we service our internal and external customers"*

ED\_001654\_00000762-00005

03/25/04

Mountaire Poultry  
P.O. Box 1320  
Millsboro, DE 19966

Attention: Mr. Jeff Smith

Lab I.D.Description

13142D

Ex. 6 - Personal Privacy

@ 0910-hrs on 3/23/04 by client:  
received 3/23/04 by CMG of EIParameterUnitsResultsTest DateTime InitMethod

Nitrate as N

mg/L

&lt; 1.0

03/24/04

950

EHK

4500D

Lab I.D.Description

13143D

Ex. 6 - Personal Privacy

@ 0913-hrs on 3/23/04 by client:  
received 3/23/04 by CMG of EIParameterUnitsResultsTest DateTime InitMethod

Nitrate as N

mg/L

1.48

03/24/04

950

EHK

4500D

Lab I.D.Description

13144D

Ex. 6 - Personal Privacy

lab @ 0918-hrs on 3/23/04 by client:  
received 3/23/04 by CMG of EIParameterUnitsResultsTest DateTime InitMethod

\* Nitrate as N

mg/L

18.1

03/24/04

950

EHK

4500D

\* Analyzed in duplicate with a relative standard deviation of +/- 4.93%

Ex. 6 - Personal Privacy

Supervising Analyst

# ENVIROCORP, INC.

## CHAIN OF CUSTODY RECORD

Mountaire Poultry  
P.O. Box 1320  
Millsboro, Delaware 19966  
Mr. Jeff Smith

LAB I.D.	TIME	DATE	DESCRIPTION	YES	NO	ANALYSES
1 13H42D	9:10 AM	3-23-04	Sample #1 - <div>Ex. 5 - Personal Privacy</div>	H2SO4		Nitrate
1	↓			Ice		Nitrite
2 13H43D	9:13 AM		Sample #2 - <div>Ex. 5 - Personal Privacy</div>	H2SO4		Nitrate
2	↓			Ice		Nitrite
3 13H44D	9:13		Sample #3 - <div>Ex. 5 - Personal Privacy</div>	H2SO4		Nitrate
3	↓			Ice		Nitrite

  

RELINQUISHED BY:	DATE	TIME	RECEIVED BY:	COMMENTS
<div>Ex. 5 - Personal Privacy</div>	3-23-04	10:05 AM		

04/12/04

Mountaire Poultry  
P.O. Box 1320  
Millsboro, DE 19966

Attention: Mr. Jeff Smith

Lab I.D.Description

13196D

**Ex. 6 - Personal Privacy**

 @ 1020-hrs on 4/2/04 by client:  
~~received 4/27/04 by CMG of EI~~ParameterUnitsResultsTest DateTime InitMethod

Nitrate as N

mg/L

2.53

04/09/04

1420

EHK

4500

**Ex. 6 - Personal Privacy**

~~Supervising Analyst~~



